

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1259

Dated. 19/12/24

It is certified that an inspection team headed by *Mr. Sandeep Lamba Sanitary Inspector*  
(Name of Officers with designation) from *Office of Municipal Corporation Chirawa*  
(Name of Department/ Office) inspected the Kishori International School C/o Satyadev  
Shikshan Sansthan, Pilani road, Chirawa, Distt- Jhunjhunu, Rajasthan (333026) (Name &  
Address of the school) on .....(date of inspection)  
and found that Kishori International School (Name of school) has safe drinking water facilities for the  
students and members of staff of the institution and is maintaining the hygienic sanitation condition in  
the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
The above is valid <sup>for</sup> a period of *one* <sup>year</sup> *years* .....

*Principal*  
Kishori International School  
(CBSE Aff. No - 1730479)  
(Chirawa (J.J.N) Raj.-333026)  
*[Signature]*

Signature with Seal .....  
Name : *अधिशारी अधिकारी*  
Designation : *नगर पालिका चिरवा*  
Name & Address of the Office / Department :  
*Satyadev Shikshan Sansthan  
(Chirawa (J.J.N) Raj.-333026)*

To  
Kishori International School  
C/o Satyadev Shikshan Sansthan  
Pilani road, Chirawa,  
Distt-Jhunjhunu  
Rajasthan (333026)  
(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

*[Signature]*  
**Secretary**  
**Satyadev Shikshan Sansthan**  
**Chirawa (Raj.) 333026**

*[Signature]*  
**Principal**  
**Kishori International School**  
**CBSE Aff.No - 1730479**  
**Chirawa (J.J.N) Raj.-333026**



## कार्यालय नगर पालिका मण्डल चिड़ावा (झुंझुनू)



Ph. 01596.220430, 220040

Email- [nagarpalika.chirawa@gmail.com](mailto:nagarpalika.chirawa@gmail.com)

क्रमांक : नपाचि / 2024-2025 / 1259

दिनांक : 19/12/24

### प्रमाण-पत्र

प्रमाणित किया जाता है कि नगरपालिका चिड़ावा के जनस्वास्थ्य शाखा के कार्यवाहक स्वास्थ्य निरीक्षक श्री सन्दीप लाम्बा की तस्दीक के आधार पर किशोरी इंटरनेशनल स्कूल पिलानी रोड़ चिड़ावा का परिसर स्वच्छ एवं सुव्यवस्थित है । विद्यालय परिसर में बच्चों के लिए शौचालय एवं पीने के पानी की सुचारु व्यवस्था है ।

अधिसायी अधिकारी  
नगरपालिका चिड़ावा  
मण्डल पालिका चिड़ावा

  
**Secretary**  
Satyadev Shikshan Sansthan  
Chirawa (Raj.) 333026

  
**Principal**  
Kishori International School  
CBSE AFF.No - 1730479  
Chirawa (JJN) Raj.-333026

Principal  
Kishori International School  
CBSE AFF.No - 1730479  
Chirawa (JJN) Raj.-333026

Secretary  
Satyadev Shikshan Sansthan  
Chirawa (Raj.) 333026



PUBLIC HEALTH ENGINEERING DEPARTMENT  
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2025-26/ 964

Date - 12-2-2026

To,  
Kishori International School  
Chirawa

District - Jhunjhunu  
Tehsil:- Chirawa  
Date of Exam -12.02.2026

Ref- Yours letter dated 11.02.2026

A	Name & Location of Source	IS-10500:2012		Water Sample Kishori International School	RO Filter Water Kishori International School
B	Village/ Town			Chirawa	Chirawa
C	Date Of Collection			11.02.2026	11.02.2026
D	Lab. Sample No.			C-183	C-184
Sr. No	Parameters	Desirable limits	Permissible limits	Value	
1	pH	6.5—8.5	6.5—8.5	7.73	7.21
2	Turbidity[NFU]	1	5	Nil	Nil
3	Temperature[C]	—	—	25	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.	Unobj.
6	Total Alkalinity[asCaCO <sub>3</sub> ]	200	600	340	60
7	Total Hardness[asCaCO <sub>3</sub> ]	200	600	170	50
8	Chloride[asCl <sup>-1</sup> ]	250	1000	200	30
9	Nitrate[as NO <sub>3</sub> <sup>-1</sup> ]	45	45	30	02
10	Fluoride [as F <sup>-1</sup> ]	1.0	1.5	0.71	0.20
11	Residual Chlorine	0.2	1.0	Nil	Nil
12	Sulphate [as SO <sub>4</sub> <sup>-2</sup> ]	200	400	146	08
13	TDS	500	2000	1142	170

Note: All Results Except pH in mg/L.

(S K Sharma)  
Junior Chemist

PHED Laboratory Jhunjhunu

Secretary

Satyadev Shikshan Sansthan  
Chirawa (Rai.) 333026

Principal

Kishori International School  
CBSE AFF.No - 1730479  
Chirawa (JJN) Raj.-333026